

Cyanuric Acid

Revised – September 2011

Brought to you by the APSP Recreational Water Quality Committee

I. INTRODUCTION

The purpose of this fact sheet is to provide a generic technical overview of cyanuric acid (CYA), which is marketed for use in stabilizing chlorine in recreational waters.

II. SUMMARY OF CHARACTERISTICS


- Stabilizes chlorine to help prevent degradation of active chlorine by sunlight
- Also commonly known as “stabilizer” or “conditioner”
- May be added to the pool as CYA, sodium salt of cyanuric acid, or as the chlorinated forms of cyanuric acid, sodium dichloro-s-triazinetrione (dichlor) and trichloro-s-triazinetrione (trichlor)
- The effect of cyanuric acid on slowing the oxidation of organics, kill rates of bacteria, viruses, and algae has been demonstrated, primarily in laboratory studies. However, disease outbreaks linked to cyanuric levels in properly sanitized pools have not been reported.
- Cyanuric acid does not stabilize bromine sanitizers
- Cyanuric acid contributes to total alkalinity (See Alkalinity Information Bulletin)

III. GENERAL DESCRIPTION


Without cyanuric acid in the water, bright sunlight can cause decomposition of most of the chlorine in pool water within an hour, as shown in the graph below. Addition of 25 ppm (mg/L) of cyanuric acid to the water can greatly slow this reduction of chlorine. Maximum stabilization occurs between 50 ppm and 100 ppm. No demonstrable increase in stabilization was seen above 100 ppm. The ideal range for cyanuric acid is 30-50 ppm when used.

This APSP Fact Sheet has been prepared from the best information available at the time of its publication and represents a consensus of the members of the APSP Recreational Water Quality Committee. The APSP makes no guarantee, and assumes no liability, in connection with any of this information. Moreover, it should not be assumed that every acceptable procedure is included, or that special circumstances may not warrant modified or additional procedures. Appropriate steps should be taken to ensure that the information is current when used. These suggestions should not be confused with federal, state, provincial, municipal or insurance requirements, or with national safety codes. This Fact Sheet is intended for the use of trained professionals in the pool and spa industry, in conjunction with prior training and knowledge. The use of information or recommendations in this Fact Sheet is voluntary and its applicability and suitability for any particular use is the sole responsibility of the user. Nothing in this Fact Sheet should be interpreted as expressing either approval of, or disapproval of, any product or service. Comments are welcome and should be submitted to APSP. © 2014 APSP.

Figure 1. Impact of sunlight on chlorine residual



When cyanuric acid is used, hypochlorous acid is always in equilibrium with cyanuric acid-bound available chlorine. As suggested by the equation below, the stabilization of chlorine residual results from a reaction of free chlorine (hypochlorous acid or hypochlorite) with cyanuric acid to give cyanuric acid-bound available chlorine.



This APSP Fact Sheet has been prepared from the best information available at the time of its publication and represents a consensus of the members of the APSP Recreational Water Quality Committee. The APSP makes no guarantee, and assumes no liability, in connection with any of this information. Moreover, it should not be assumed that every acceptable procedure is included, or that special circumstances may not warrant modified or additional procedures. Appropriate steps should be taken to ensure that the information is current when used. These suggestions should not be confused with federal, state, provincial, municipal or insurance requirements, or with national safety codes. This Fact Sheet is intended for the use of trained professionals in the pool and spa industry, in conjunction with prior training and knowledge. The use of information or recommendations in this Fact Sheet is voluntary and its applicability and suitability for any particular use is the sole responsibility of the user. Nothing in this Fact Sheet should be interpreted as expressing either approval of, or disapproval of, any product or service. Comments are welcome and should be submitted to APSP. © 2014 APSP.

This reaction is totally reversible, with a back reaction (to again reform hypochlorous acid) fast enough that cyanurate-bound chlorine tests as free chlorine. Free chlorine that has reacted with cyanuric acid is not permanently lost, but rather placed temporarily in reserve. However the affinity of chlorine for cyanuric acid is strong enough that most of the “Free Available Chlorine” at any given point in time is bonded to cyanurate and the hypochlorous acid concentration is only a fraction of what a free available chlorine test and pH would indicate. This is reflected in an Oxidation Reduction Potential (ORP) that decreases as the cyanuric acid concentration increases as shown in laboratory studies.

Note: A molecule of cyanuric acid can react reversibly with up to three molecules of hypochlorous acid.

Lowering the hypochlorous acid concentration can have a significant impact on the rates of any reaction for which hypochlorous acid is involved in a rate limiting step. Specifically disinfection and oxidation of contaminants can be slowed by the lowered hypochlorous acid concentration.


Generally speaking, the rate of disinfection or the rate of oxidation of a contaminant in the water by hypochlorous acid could be described by the following equation:

$$-dN/dt = k [HOCl]^a N$$

in which:

- N represents a microbial concentration (such as deduced by a plate count) of the microbe to be killed or the concentration of the oxidizable species (such as various organic compounds, breakpoint susceptible chloramines, sulfide, or nitrite) to be destroyed;
- $-dN/dt$ represents the rate of loss of the microbe or oxidizable material;
- k represents a rate constant; a is a positive real number that is specific to the type of reaction involved; and
- $[HOCl]$ represents the hypochlorous acid concentration.

If this rate dependence on hypochlorous acid concentration is considered with the following equilibrium, it can be seen that increasing cyanuric acid will decrease the HOCl concentration which could have a negative impact on sanitization and oxidation rates.



The effect of cyanuric acid on oxidation of organics, kill rates of bacteria and viruses, algae, and protozoa has been demonstrated. Some authorities or standards have suggested adjusting the required chlorine residual to the concentration of cyanuric acid to compensate for the reduction in rates of kill. These studies are not fully comprehensive and applicability to real pools has not been demonstrated. Specifically, we do not have any empirical evidence that a disease outbreak has been linked to a particular cyanuric acid level in a properly sanitized pool (i.e., when at least 1 ppm free available chlorine was present in the pool).

IV. APPLICATION

Application methods will depend upon the product form being used. Cyanuric acid is available in both granular and liquid slurry forms. Since the granular form is slow to dissolve, if it is fed into the skimmer, care must be taken to feed the product slowly to avoid blocking the lines. Most granular cyanuric acid products are approximately 100% active. The following table summarizes the cyanuric acid contributions from dichloro-s-triazinetrione and trichloro-s-triazinetrione.

Pounds of cyanuric acid contributed to the pool for every pound of product:

Product	One pound product contains x pounds of cyanuric acid
Sodium dichloro-s-triazinetrione	0.58
Sodium dichloro-s-triazinetrione dihydrate	0.50
Trichloro-s-triazinetrione	0.55

This APSP Fact Sheet has been prepared from the best information available at the time of its publication and represents a consensus of the members of the APSP Recreational Water Quality Committee. The APSP makes no guarantee, and assumes no liability, in connection with any of this information. Moreover, it should not be assumed that every acceptable procedure is included, or that special circumstances may not warrant modified or additional procedures. Appropriate steps should be taken to ensure that the information is current when used. These suggestions should not be confused with federal, state, provincial, municipal or insurance requirements, or with national safety codes. This Fact Sheet is intended for the use of trained professionals in the pool and spa industry, in conjunction with prior training and knowledge. The use of information or recommendations in this Fact Sheet is voluntary and its applicability and suitability for any particular use is the sole responsibility of the user. Nothing in this Fact Sheet should be interpreted as expressing either approval of, or disapproval of, any product or service. Comments are welcome and should be submitted to APSP. © 2014 APSP.

Dosage and application requirements will be explained on each product label.

When used, the ideal range for cyanuric acid is 30 – 50 ppm. The concentration should not exceed 100 ppm. Cyanuric acid is not recommended for indoor pools or spas where protection from sunlight is not necessary.

The 100 ppm limit is a common consensus among health authorities, for example:

CDC	100 ppm
WHO	100 ppm
Ten State Standard	100 ppm

There is a degree of uncertainty in setting this value, but the consensus decision is not entirely arbitrary. The following factors were considered when setting the limit for cyanuric acid:

- Effective use levels of cyanuric acid;
- Cyanuric acid/chlorine equilibria;
- Effect of cyanuric acid on Oxidation Reduction Potential (ORP); and
- Effect of cyanuric acid on chlorine kill rates.

Test kits and strips are available for testing the cyanuric acid concentration to ensure that it is within the proper range.

If the cyanuric acid concentration needs to be reduced the following approaches may be used:

- Partially drain and refill the pool
- Increase backwash times or frequency
- Follow appropriate water replacement intervals

V. PRECAUTIONS

In order to safely use and handle cyanuric acid products, all individuals involved in their manufacture, distribution, sale, or use should be trained and knowledgeable about their properties. Safety information is available on the product label, product MSDS (Material Safety Data Sheet), and manufacturer's training materials. This safety information will include disposal instructions, instructions on disposal of the package, and spill response information.

For safety and handling information for stabilized chlorine compounds, refer to manufacturer's labels and appropriate Information Bulletins. Cyanuric acid is stable when stored in a cool, dry, ventilated area and not contaminated by other chemicals such as bases or chlorinated pool chemicals. Cyanuric acid, dichloro-s-triazinetione and trichloro-s-triazinetriene, in the solid form or in concentrated solutions, shall not be mixed with other pool chemicals including other chlorinating agents. Partially empty packages must not be consolidated, as this could result in dangerous mixing with incompatible dry chlorinating agents having a similar appearance.

VI. REFERENCES

1. U.S. Centers for Disease Control and Prevention and U.S. Department of Housing and Urban Development. Healthy housing reference manual. Chapter 14. Atlanta: US Department of Health and Human Services; 2006. <http://www.cdc.gov/nceh/publications/books/housing/housing.htm#CONTENTS>
2. Guidelines for Safe Recreational Water Environments, Volume 2, Swimming Pools and Similar Environments, World Health Organization, 2006, ISBN 92-4-154680-8, page xvii, http://www.who.int/water_sanitation_health/bathing/bathing2/en/
3. Recommended Standards for Swimming Pool Design and Operation. Great Lakes – Upper Mississippi River Board of State and Provincial Public Health and Environmental Managers, Illinois, Indiana, Iowa, Michigan, Minnesota, Missouri, New York, Ohio, Ontario, Pennsylvania, Wisconsin, 1996 Edition, Published by: Health Education Services, P.O. Box 7126, Albany, NY 12224, Phone: 518-439-7286
4. PSEUDOMONAS DERMATITIS/FOLLICULITIS ASSOCIATED WITH POOLS AND HOT TUBS --- COLORADO AND MAINE, 1999—2000, DECEMBER 08, 2000 / 49(48);1087-1091
5. <http://www.cdc.gov/mmwr/preview/mmwrhtml/mm4948a2.htm>
6. Golaszewski, G., Clement, M., Seux, R., Influence of isocyanuric acid on the reactivity of chlorine with creatinine in swimming pool water, Journal Francais d'Hydrologie, 1988, 19, Fasc. 2, 179-190.

This APSP Fact Sheet has been prepared from the best information available at the time of its publication and represents a consensus of the members of the APSP Recreational Water Quality Committee. The APSP makes no guarantee, and assumes no liability, in connection with any of this information. Moreover, it should not be assumed that every acceptable procedure is included, or that special circumstances may not warrant modified or additional procedures. Appropriate steps should be taken to ensure that the information is current when used. These suggestions should not be confused with federal, state, provincial, municipal or insurance requirements, or with national safety codes. This Fact Sheet is intended for the use of trained professionals in the pool and spa industry, in conjunction with prior training and knowledge. The use of information or recommendations in this Fact Sheet is voluntary and its applicability and suitability for any particular use is the sole responsibility of the user. Nothing in this Fact Sheet should be interpreted as expressing either approval of, or disapproval of, any product or service. Comments are welcome and should be submitted to APSP. © 2014 APSP.

7. Frederick W. Pontius (technical editor)/American Water Works Assoc., "Water Quality and Treatment: A Handbook for Community Water Supplies", 4th Edn., New York: McGraw-Hill, 1990, pp. 899-904. [ISBN 0-07-00154-6]
8. Golaszewski, G., Clement, M., Seux, R., Influence of isocyanuric acid on the reactivity of chlorine with creatinine in swimming pool water, Journal Francais d'Hydrologie, 1988, 19, Fasc. 2, 179-190.
9. Andersen, J. R., A study of the influence of cyanuric acid on the bactericidal effectiveness of chlorine, American Journal of Public Health, 1965, 55(10), 1629-1637.
10. Fitzgerald, G. P., DerVartanian, M. E. Pseudomonas aeruginosa for the evaluation of swimming pool chlorination and algicides, Applied Microbiology, 1969, 17(3), 415-421.
11. LeGuyader, M., Grateloup, I., Relative importance of different bacteriological parameters in swimming pool water treated by hypochlorite or chloroisocyanurates, Journal Francais d'Hydrologie, 1988, 19, Fasc 2, 241-250.
12. Robinton, E.D., and Mood, E.W., An evaluation of the inhibitory influence of cyanuric acid upon swimming pool disinfection. American Journal of Public Health, 1967, 57(2) :301-310.
13. Yamashita, T., Sakae, K., Ishihara, Y., Inoue, H., and Isomura, S. 1985. Influence of cyanuric acid on viricidal effect of chlorine and the comparative study in actual swimming pool waters. Kansenshogaku Zasshi, March 3, 1988, 62(3), 200-205.
14. Sommerfeld, M. R., Adamson, R. P., Influence of stabilizer concentration on effectiveness of chlorine as an algicide, Applied and Environmental Microbiology, Feb 1982, 43(2), 497-499.
15. Centers for Disease Control and Prevention, Fecal Accident Response Recommendations for Pool Staff, revised December 2007, http://www.cdc.gov/healthyswimming/pdf/Fecal_Accident_Response_Recommendations_for_Pool_Staff.pdf
16. 27 Australian Standard® "Private swimming pools—Water quality", AS 3633—1989, Standards Australia (Standards Assoc. of Australia), ISBN 0 7262 5957 8, Table 3.2 (section 3.2, p.10).
17. 28 Pennsylvania Department of Health, "Fact Sheet on Cyanuric Acid and Stabilized Chlorine Products", 7/24/2003, <http://www.dsf.health.state.pa.us/health/cwp/view.asp?a=180&q=234664>.
18. 30 Jacques M. Steininger, "PPM or ORP: Which Should Be Used?", Swimming Pool Age & Spa Merchandiser, November 1985, <http://www.sbcontrol.com/ppmorp.pdf>.
19. 31 Wisconsin Administrative Code HFS 172 "Safety, Maintenance And Operation Of Public Swimming Pools and Water Attractions", Subchapter II—Water Treatment Systems and Water Quality, Section HFS 172.14 "Disinfectant Feeding And Residuals" Paragraph (4) "Chemical Concentrations and Residuals", Wisconsin Department of Health and Family Services, Register, August, 2007, No. 620, <http://www.legis.state.wi.us/rsb/code/hfs/hfs172.pdf>
20. 32 65529 "Disinfection, pH Control and Cyanuric Acid", California Code of Regulations, Title 22, Chapter 20, (Public Swimming Pools), Article 3 (Maintenance and Operation), p.12, <http://www.solanocounty.com/resources/ResourceManagement/poolcode.pdf>.
21. Hammond, B.G., S.J. Barbee, T. Inoue, N. Ishida, G.J. Livinskas, M.W. Stevens, A.G. Wheeler and T. Cascieri. 1986. A Review of Toxicology Studies on Cyanurate and its Chlorinated Derivatives. Environmental Health Perspectives 69: 287-292.

This APSP Fact Sheet has been prepared from the best information available at the time of its publication and represents a consensus of the members of the APSP Recreational Water Quality Committee. The APSP makes no guarantee, and assumes no liability, in connection with any of this information. Moreover, it should not be assumed that every acceptable procedure is included, or that special circumstances may not warrant modified or additional procedures. Appropriate steps should be taken to ensure that the information is current when used. These suggestions should not be confused with federal, state, provincial, municipal or insurance requirements, or with national safety codes. This Fact Sheet is intended for the use of trained professionals in the pool and spa industry, in conjunction with prior training and knowledge. The use of information or recommendations in this Fact Sheet is voluntary and its applicability and suitability for any particular use is the sole responsibility of the user. Nothing in this Fact Sheet should be interpreted as expressing either approval of, or disapproval of, any product or service. Comments are welcome and should be submitted to APSP. © 2014 APSP.